

Ref Nr: Oprs.073-2014

**To whom it may concern,**

We hereby as EFECTIS ERA AVRASYA Laboratories confirm that;

The resistance to fire test was carried out on 21.11.2014 at Efectis Era Avrasya Test Laboratories in accordance with EN 1363-1 and EN 1634-1 standards for the product which was manufactured by **ORSEP MOB. DEK. İNŞ. SAN. TİC. LTD. ŞTİ.** as described below.

**Product:**

Single Leaf Timber Door – **YD-01**

**Direction of Fire:**

Hinges turning into the fire

**Resistance to fire classification**

**EI<sub>1</sub>45; EI<sub>2</sub>45**

- The preparation process of reports is in progress.

APPENDIX 1: Technical drawings of product.

Best regards,

25.11.2014

\_\_\_\_\_  
Kocaeli



\_\_\_\_\_  
Onur DAĞ  
Operation Manager

## APPENDIX 1:

